

CMS Messaging Report

Project: WCSDDDRYS Version: 01.00.04 Nut. SCS.

Account Message ACCT

Cabinet Message (Number) Cab1 (01)

MODCOMLabel (Slot): 3-MODCOM_01_05 (05)

CMS Account #: 9192

Dial Test Interval: 1 Days 0 Hours 0 Minutes

Account Description: CMS

Receiver Message: ACCT

Receiver Protocol: CONTACT ID

Receiver Phone Number(s): 918778373961 : 918554320883

Dial Test Time Of Day: 7:00:00 AM

Message Sent:	Activating Event	Device Type	Activating Device Location Text
111000009	ALARM Activation	SMOKE	SMOKE FACP ROOM
311000009	ALARM Restoration	SMOKE	SMOKE FACP ROOM
111000010	ALARM Activation	SMOKE	KITCHEN SIDE SMOKE DOORS
311000010	ALARM Restoration	SMOKE	KITCHEN SIDE SMOKE DOORS
111000011	ALARM Activation	SMOKE	DOCK SIDE SMOKE DOORS
311000011	ALARM Restoration	SMOKE	DOCK SIDE SMOKE DOORS
111000001	ALARM Activation	WATERFLOW	WATERFLOW ALARM
311000001	ALARM Restoration	WATERFLOW	WATERFLOW ALARM
120000001	SUPERVISORY Activation	TAMPER	RISER VALVE TAMPER
320000001	SUPERVISORY Restoration	TAMPER	RISER VALVE TAMPER
120000002	SUPERVISORY Activation	TAMPER	ZONE 3 TAMPER PV
320000002	SUPERVISORY Restoration	TAMPER	ZONE 3 TAMPER PV
120000003	SUPERVISORY Activation	TAMPER	DOCK GLYCOL LOOP TAMPER
320000003	SUPERVISORY Restoration	TAMPER	DOCK GLYCOL LOOP TAMPER
111000002	ALARM Activation	SMOKE	SMOKE ZONE ALARM
311000002	ALARM Restoration	SMOKE	SMOKE ZONE ALARM
111000003	ALARM Activation	PULL	ZONE 6 PULLS - OFFICE, RECEPTION, MECH
311000003	ALARM Restoration	PULL	ZONE 6 PULLS - OFFICE, RECEPTION, MECH
111000004	ALARM Activation	PULL	ZONE 7 PULLS - WEST DOCK, DRY STORAGE
311000004	ALARM Restoration	PULL	ZONE 7 PULLS - WEST DOCK, DRY STORAGE
111000005	ALARM Activation	GENALARM	ANSUL KITCHEN HOOD
311000005	ALARM Restoration	GENALARM	ANSUL KITCHEN HOOD
120000004	SUPERVISORY Activation	SUPERVISORY	DUCT SMOKE DETECTORS
320000004	SUPERVISORY Restoration	SUPERVISORY	DUCT SMOKE DETECTORS
111000006	ALARM Activation	PULL	ZONE 10 PULL - 2ND FLOOR
311000006	ALARM Restoration	PULL	ZONE 10 PULL - 2ND FLOOR