

Signature Series Configuration

Cabinet: Cab1

Cabinet Number: 1

3-SSDC1: 3-SSDC1_01_04

Slot: 4

Signature Series Parameters

Loop 1 Detectors

Loop 1 Modules

Loop 1

☐ Enable Mapping

☐ Class A

☒ Class B

CC2A Capacitance Discharge

COS Default Values

Detectors

COS

HCOS

IPHS

IS

PCOS

PHCOS

PHS

PS

CO Setting

COSUPERVISORY

Base Defaults

Relay

☒ Follow Local Alarm

☐ Follow Alarm Verification

☐ Follow Local Pre-Alarm

☐ Device in Alarm Overrides Silence

Sounder

☒ Follow Local Alarm

☒ Follow Alarm Verification

☒ Follow Local Pre-Alarm

☒ Device in Alarm Overrides Silence

01020672Map Fault	DataCard1						All_Msg_Annunciation_Groups_Route
01020673Mapping In	Progress DataCard1						All_Msg_Annunciation_Groups_Route
01020674Mapping	Disabled DataCard1						No_Msg_Annunciation_Groups_Route
01020675Dev. Maintnc	Alert DataCard1						All_Msg_Annunciation_Groups_Route